


Addendum to the 2011 Lift Code

Paragraph in the Code	Amendments
3.2.7	This paragraph is amended to delete “Inspection doors, emergency doors and”
3.2.8	<p>This paragraph is amended to:</p> <p>“Inspection and emergency doors shall:</p> <ul style="list-style-type: none"> (a) be equipped with dual key-operated locks requiring the simultaneous operation of two designated keys for opening from the outside and capable of being reclosed and relocked without a key; (b) be capable of being opened from inside the well without a key even when locked; and (c) except for doors in the form of lift landing doors, bear on its outside face a prominent figure-type warning sign of size not less than 100 mm high and immediately above or next to the keyholes of such doors as shown below- <div style="text-align: center;">  </div> <p style="text-align: right;">”</p>
3.2.9	<p>New paragraph is added:</p> <p>Where the design and disposition of liftwell inspection and emergency doors can reduce the likelihood of inadvertent entry, paragraph 3.2.8(a) is not applicable and a single locking device operated by a designated key is acceptable. Typical examples are:</p> <ul style="list-style-type: none"> (a) lift landing doors serving as the liftwell inspection and emergency doors; or (b) liftwell inspection and emergency doors with their sills being 1 m or more above the adjoining floor.

(08/2015)