

**Summary of Decision of the Building Committee**  
**Building Committee II 4/2024 held on 31.7.2024**

(a) BCII 1 4/2024

Issues : Performance-based approach to assess the provision of natural lighting and ventilation for habitable rooms and open kitchens.

Decisions : Noting that the simulation conducted was generally in line with the guidelines in PNAP APP-130 and the relevant conditions in the PNAP were met, the committee agreed to adopt the performance-based approach.